

## Public Notice of SSO (Sanitary Sewer Overflow)

At approximately 1:00 P.M. on Monday, June 8<sup>th</sup>, 2020 staff at the City of Mayville Utilities discovered a overflow of wastewater from a broken force main near 605 Fourth Street. It is estimated that approximately 300 gallons of the 5496 gallons that was pumped during that time reached the surface of the paved roadway on Fourth Street. Traffic was redirected to avoid the spill area entirely and flows were bypassed to avoid additional contamination while repair crews corrected the issue. The repairs were completed and road was back in service by 8:30 p.m. An overflow is defined as a release of wastewater from a sewage collection system (SSO) or treatment facility (TFO). This notification is published in accordance with Wis. Adm. Code 283.55(1)(dm), Wis. Stats. s. NR 210.21(4)(5)(6) and in accordance with WPDES permit requirements.